



Product Service

Attestation of Conformity

No. N8A 112735 0002 Rev. 00

Holder of Certificate:	Lulu Electric Inc. No.188, Xinghuo Rd., Fengxian 201400 Shanghai PEOPLE'S REPUBLIC OF CHINA
Product:	Switches Firefighter safety switch
Model(s):	LFS-S1, LFS-S2, LFS-S3, LFS-S4, LFS-S5 LFS-S6, LFS-S7, LFS-S8, LFS-S9, LFS-S10
Parameters:	Rated operational voltage (Ue): 600VDC, 800VDC, 1000VDC, 1200VDC, 1500VDC Rated operational current (Ie): 30A Rated insulation voltage (Ui): 1500V Rated impulse withstand voltage (Uimp): 8kV Conventional free air thermal current (Ith): 50A Rated short-circuit making capacity (Icm) (peak): 780A Degree of protection: IP67 (except for terminals) Number of poles: 2, 4, 6, 8, 10, 12, 14, 16, 18, 20 Utilization Category: DC-PV1
Tested according to:	EN IEC 60947-3:2021 EN IEC 60947-1:2021

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for testing and certification. For details see: www.tuvsud.com/ps-cert

Test report no.: 704102163001-00

Date, 2021-08-24

(Jie Zhu)

Page 1 of 1

After preparation of the necessary technical documentation as well as the EU declaration of conformity the required CE marking can be affixed on the product. The declaration of conformity is issued under the sole responsibility of the manufacturer. Other relevant EU-directives have to be observed.